## **Generator Inspection Check List**

	Date:		
Generator Location: Buildings Serviced by Generator:			
Checl	k List:		
1.	Check generator for overall condition (loose or missing parts, open or missing panels, loose wiring, etc.). Describe any problem conditions below.		
2.	Are there any leaks?	Yes	□No
3.	Cooling system coolant level normal?	Yes	No
4.	Oil level normal?	Yes	□No
5.	Battery condition, wire connections, acid leaks, and electrolyte levels?	Yes	□No
6.	Fan belts and other drive belts in good condition and with proper tension?	Yes	No
7.	Engine oil heater working?	Yes	No
8.	Check exhaust system for leaks and overall condition. Describe any problems below.		
9.	Record fuel level (if applicable).		
10.	If load test is conducted, record run information	below.	
	<ul> <li>a. Time switch transferred:</li></ul>		PSI °F
	Phase A:Volts	Amps	Hz
	Phase B:Volts	Amps	Hz
	Phase C:Volts	Amps	Hz
	f. Current run hour meter reading:		
11.	Fire extinguisher charged and inspected recently	? Yes	No
Com	ments:		